

Table of contents

1	Scope of application	11
1.1	Introduction	11
1.2	Field of application	11
1.3	Influence of the generating unit protection on the configuration of the unit auxiliary supply protection	12
2	Description of the protection functions	13
2.1	Protection of the generator	13
2.1.1	Time overcurrent protection	13
2.1.2	Impedance Protection	13
2.1.3	Unbalanced load protection	14
2.1.4	Asymmetry protection (loss of phase protection)	15
2.1.5	Overvoltage protection	17
2.1.6	Undervoltage protection	17
2.1.7	Under-frequency protection	18
2.1.8	Power plant de-coupling protection	18
2.1.9	Over-frequency protection	18
2.1.10	Pole slip protection (out-of-step protection)	18
2.1.11	Differential protection	19
2.1.12	Earth fault differential protection	20
2.1.13	Winding short-circuit protection for existing plant	20
2.1.14	Stator earth fault protection	21
2.1.15	Rotor earth fault protection	22
2.1.16	Under-excitation protection	23
2.1.17	Rotor overload protection	24
2.1.18	Reverse power protection	24
2.1.19	Circuit-breaker failure protection (50BF)	24
2.1.20	Special aspects in the case of generator rotation reversal	25
2.1.21	Particularities with variable speed plants (Pumped-storage power plants)	26
2.2	Protection of the generator transformer	26
2.2.1	Differential protection	26
2.2.2	Distance protection	27
2.2.3	Earth fault protection on HV-side of the generator transformer	27
2.2.4	Start-up earth fault protection (earth fault protection on the LV-side of the generator unit transformer ...	28
2.2.5	Overexcitation protection (U/f)	28
2.2.6	Buchholz protection	28
2.2.7	Tank Ground Protection	28
2.2.8	Other protection and monitoring systems of the generator transformer ...	29

2.3	Protection of the unit auxiliary transformer	29
2.3.1	Differential protection.....	29
2.3.2	Overcurrent time protection on the HV side (generator side)	29
2.3.3	Buchholz protection	29
2.3.4	Overcurrent time protection on the LV side (auxiliary supply side)	29
2.3.5	Overvoltage protection	30
3	Protection of external network transformers	31
3.1	Auxiliary supply protection	31
3.2	Additional protection requirements	31
4	Functional schematic (diagram) of the protection	32
5	Construction and performance of the protection	35
5.1	Scope (range) of protection functions and allocation.....	35
5.2	Measures against under and over-function	36
5.3	Measures in the event of a failure of the generator CB	37
5.4	Auxiliary DC supply	37
5.5	Tripping circuits	45
5.6	Protection cubicles	46
5.7	Physical location.....	47
5.8	Auxiliary and interface relays.....	47
5.9	Terminal strips	48
5.10	Cables	51
5.11	Handling Firmware updates.....	51
6	Other equipment and functions	53
6.1	Current transformers	53
6.2	Voltage transformers	54
6.3	Monitoring the measuring circuits	54
6.4	Capacitors on the Low Voltage (undervoltage) side of the generating transformer	54
6.5	Surge arresters.....	54
6.6	Relays and switchgear	55
6.6.1	Generator circuit-breaker.....	55
6.6.2	Grid Circuit Breaker	56
6.6.3	De-excitation devices	56
6.6.4	Automatic unit auxiliary supply transfer switching	56
6.6.5	Unit auxiliary supply circuit-breaker	56
6.6.6	Quick action valves.....	57
6.7	Coupling of external signals	57
6.8	Information exchange, trip communication	58
6.9	Alarming devices	58

6.10	Deluge sprinkler systems	59
6.11	Monitoring of the generator closed circuits	59
6.12	Monitoring of the excitation systems	60
7	Testing the protection	61
7.1	General	61
7.2	Organisation of the testing	61
7.2.1	Tests at the manufacturing plant (factory acceptance tests)	61
7.2.2	Initial Commissioning	61
7.2.2.1	Pre-testing	61
7.2.2.2	Commissioning tests	62
7.2.3	Re-testing	66
7.2.3.1	Primary tests	66
7.2.3.2	Secondary tests	66
7.3	Test equipment	68
7.3.1	Portable test and measuring devices	68
7.3.2	Stationary test equipment	68
8	Literature	69
9	Abbreviations	71
10	Tables	72
11	Figures	73
Annex		74